

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-0026:235 Page 1 of 1

**CATEGORY:** Fire Alarm Device for the Hearing Impaired

**LISTEE:** Simplex, 100 Simplex Drive, Westminter, MA 01441  
Contact: Paul Mattern (978) 731-8542 \*Fax (978) 731-8881

**DESIGN:** Models "*TrueAlert non-addressable*" 4904-9331, 4904-9342, 4904-9332, 4904-9343, 4904-9333 and 4904-9344 synchronized strobe lights.

Models "*TrueAlert non-addressable*" 4904-9168, 4904-9171, 4904-9169, 4904-9172, 4904-9170 and 4904-9173 non-synchronized strobe lights.

Models "*TrueAlert addressable*" 4904-9350, 4904-9351, 4904-9352, 4904-9353, 4904-9354, 4909-9355 synchronized strobe lights.

Models "*TrueAlert addressable*" 4904-9356, 4904-9357, 4904-9358, 4904-9359, 4904-9360, 4909-9361 synchronized strobe lights.

Model 4905-9938 sync control module.

Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 4904-9331, -9342, -9350, -9351, -9356, -9357, -9168, -9171: 15cd, 1 Hz.  
4904-9332, -9343, -9169, -9172, -9352, -9353, -9358, -9359: 75cd, 1 Hz.  
4904-9333, -9344, -9170, -9173, -9354, -9355, -9360, -9361: 110cd, 1 Hz.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Intended for indoor use and wall mounting only.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as strobe lights suitable for the hearing impaired when used with listee's separately listed fire alarm control units. For "*TrueAlert non-addressable*" synchronized strobes, Model 4905-9938 sync control module must be used.

\*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MAY 13, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager